

# FULL QUALITY ASSURANCE CERTIFICATE

Certificate No.:  
106982-2011-CE-ITA-ACCREDIA

Initial date:  
09 January, 2006

Validity:  
07 May, 2019 – 07 April, 2021

This certificate consists of 2 pages

This is to certify that the quality system of

## EUROKLIMAT S.p.A.

Via Liguria, 8 – 27010 Siziano (PV) - Italy

has been assessed and found to comply with respect to the conformity assessment procedure described in:

### ANNEX III MODULE H OF DIRECTIVE 2014/68/EU ON PRESSURE EQUIPMENT

This certificate is valid for the following scope:

Type of Pressure Equipment	<b>Assembly</b>
Product Name	<b>Air conditioning, liquid chillers and refrigeration system</b>

Place and date:  
Vimercate 09 May, 2019



SGQ N° 003 A      EMAS N° 009 P  
SGA N° 003 D      PRD N° 003 B  
SGE N° 007 M      PRS N° 004 C  
SOR N° 004 F      SSI N° 002 G

Membro di MLA EA per gli schemi di accreditamento  
SGQ, SGA, PRD, PRS, ESR, GHG, LAB e LAT; di MLA IAF  
per gli schemi di accreditamento SGQ, SGA, SSI, FSM  
e PRD e di MRA ILAC per gli schemi di accreditamento  
LAB, MED, LAT e ISP.

For the notified body 0496:  
**DNV GL Business Assurance Italia  
S.r.l.**

**Nicola Privato**  
Management Representative

Certificate No.: 106982-2011-CE-ITA-ACCREDIA  
 Place and date: Vimercate 09 May, 2019  
 Revision No: 06

### Jurisdiction

Application of Directive 2014/68/EU and Decreto Legislativo n. 26 of 15 February 2016

### Certificate history

Revision	Description	Issue date
00	CE PED.12.0001.06/2323 original certificate No.0496	09 January,2006
01	CE PED.12.0001.06/2323.1 Scope of extension	15 April,2011
02	Scope extension - propane	28 November,2011
03	Renewal	17 May,2012
04	Renewal	24 April,2015
05	Renewal	12 June,2018
06	Scope extension: design pressure up to 45 bar, external design temperature -20°C/+55°C, new fluids added	09 May, 2019

### Products covered by this certificate

Product name	Product description
Air Conditioning package	With air cooled condenser With liquid cooled condenser With or without Heat pump ( as required )
Liquid Chiller package	With air cooled condenser With liquid cooled condenser With or without Heat pump ( as required )
Split Unit	With remote air cooled condenser With remote liquid cooled condenser With or without Heat pump ( as required ) Air handling unit

### Sites covered by this certificate

Site name	Site Address	Audited by	Date	Report ref
EUROKLIMAT S.p.A.	Via Liguria,8 -27010 Siziano (PV)- Italy	Savino Grieco Milan Unit -PA	14-15 March, 2019	85950493 -20190315- P1-PED Mod.H-GRI

### Applications/limitations

- Category : up to III
- Design pressure : up to 45 bar (for R410A)
- External design temperature : -20°C / +55 °C
- Fluids used on above packages:
  - > Family HC - Group 1 – Type R290 (propane)
  - > Family HFC – Group 1 -Type R32
  - > Family HFC – Group 2 -Type R134a, R404A, R407C, R410A, R449A, R513A
  - > Family HFO – Group 2 -Type R1234ze

### Terms and conditions for the certificate

Valid terms and conditions are found in the DNVGL's PED Certification Rules

END OF CERTIFICATE