

# FULL QUALITY ASSURANCE CERTIFICATE

Certificate No.:  
106982-2011-CE-ITA-ACCREDIA

Initial date:  
09 January, 2006

Validity:  
05 June, 2023 - 07 April, 2024

This certificate consists of 3 pages

This is to certify that the quality system of:

**EUROKLIMAT S.p.A.**  
Via Liguria, 8 – 27010 Siziano (PV) - Italy

has been assessed and found to comply with respect to the conformity assessment procedure described in:

**ANNEX III MODULE H OF DIRECTIVE 2014/68/EU ON PRESSURE EQUIPMENT**

This certificate is valid for the following scope:

Type of Pressure Equipment	<b>Assembly</b>
Product Name	<b>Air conditioning, liquid chillers and refrigeration system</b>

Place and date:  
Vimercate, 05 June, 2023

Check Validity



SGQ N° 003 A	EMAS N° 009 P
SGA N° 003 D	PRD N° 003 B
SGE N° 007 M	PRS N° 094 C
SCR N° 004 F	SSI N° 002 G

Membro di MLA EA per gli schemi di accreditamento SGQ, SGA, PRD, PRS, ISP, GHG, LAB e LAT, di MLA IAF per gli schemi di accreditamento SGQ, SGA, SSI, FSM e PRD e di MRA ILAC per gli schemi di accreditamento LAB, MED, LAT e ISP

For the issuing office:  
Notified Body 0496, Italy  
DNV Business Assurance Italy S.r.l.



**Maurizio Bellina**  
Management Representative

## Jurisdiction

Application of Directive 2014/68/EU and Decreto Legislativo n. 26 of 15 February 2016.

## Certificate history:

Revision	Description	Issue Date
00	CE PED.12.0001.06/2323 original certificate No. 0496	09 January, 2006
01	CE PED.12.0001.06/2323.1 Scope of extension	15 April, 2011
02	Scope of extension - propane	28 November, 2011
03	Renewal	17 May, 2012
04	Renewal	24 April, 2015
05	Renewal	12 June, 2018
06	Scope of extension: design pressure up to 45 bar, external design temperature – 20°C/+55°C, new fluids	09 May, 2019
07	Renewal	19 May, 2021
08	Scope Extension; for the addition of new cooling gases.	05 June, 2023

## Products covered by this Certificate:

Product Name	Product Description	Applied product standard
Air conditioning package	With air cooled condenser With liquid cooled condenser With or without Heat pump (as required)	EN 378-2:2016
Liquid Chiller package	With air cooled condenser With liquid cooled condenser With or without Heat pump (as required)	EN 378-2:2016
Split unit	With remote air-cooled condenser With liquid cooled condenser With or without Heat pump (as required) Air handling unit	EN 378-2:2016

## Sites covered by this certificate

Site Name	Site Address	Audited by	Date	Report ref
EUROKLIMAT S.p.A.	Via Liguria, 8 - 27010 Siziano (PV) - Italy	Gianfranco Dozzo Milan/PA	12 May, 2023	ML1173-SC277986-20230512-SE_PED-PER-DOG.

## Applications/limitations

- Category: up to III
- Design pressure: up to 45 bar (for R410A)
- External design temperature: - 20°C / + 55°C
- Fluids used on above packages:
- Family HC - Group 1 - Type R290 (propane), *R600a*
- Family HFC - Group 1 - Type R32, *R454B, R454C*
- Family HFC - Group 2 - Type R134a, R404A, R407C, R410A, R449A, R513A
- Family HFO - Group 2 - Type R1234ze, *R1234yf*

## Terms and conditions

Valid terms and conditions are found in the DNV's PED Certification Requirements

End of Certificate